

PIONEER GALAXY™ Water Tanks

Standard Tank Sizes and Sand Pad Requirements

PIONEER GALAXY™ Tank Range	Tank Dimensions		Total Tank Volume		Pad Size	Minimum San Required
	Diameter	Height	US Gallons	Liters	(Diameter x Depth)	(approx)*
XL 08/02	15' 5"	7' 3"	9,927	37,573	21' 5" x 6"	10 cubic yards
XL 13/02	19' 9"	7' 3"	16,410	62,111	25' 9" x 6"	14 cubic yards
XL 15/02	22'	7' 3"	20,259	76,680	28' x 6"	17 cubic yards
XL 23/02	26' 4"	7' 3"	29,173	110,419	32' 4" x 6"	24 cubic yards
XL 30/02	30' 9"	7' 3"	39,707	150,292	36' 9" x 6"	30 cubic yards
XL 40/02	35' 2"	7' 3"	51,863	196,300	41' 2" x 6"	38 cubic yards
XL 50/02	39' 6"	7' 3"	65,639	248,442	45' 6" x 6"	48 cubic yards

*Area and amount of clean sand required to prepare site for your PIONEER GALAXY™ water tank. In some applications a concrete ring beam will be required. BlueScope Water can provide further information about ring beam requirements.